

1. IF DISTANCE A IS 5' OR LESS, ROTATE MAIN SERVICE TEE AND RECONNECT SERVICE AS PER DETAIL I. IF A IS GREATER THAN 5' INSTALL RISER AS PER DETAIL II.
2. WHERE DEPTH IS INSUFFICIENT TO ALLOW RE-CONNECTION AS SHOWN IN DETAIL I OR II, RE-CONNECT SERVICE AS DIRECTED BY ENGINEER.

- A. VARIABLE WITH A MAX. OF 5'.
- B. 1' MIN., 1.5' MAX.
- C. ELBOWS, 45° DEFLECTION MAX.
- D. INSTALL CONCRETE GRADLE ON TEE AS PER DWG. 2135, RIGID PIPE ONLY.
- E. SERVICE TEE.
- F. EXIST. SERVICE LINE.
- G. VARIABLE LENGTH.
- H. BACKFILL UNDER SERVICE WITH MIN. 1 CUBIC FOOT OF PC. CONCRETE ('SACKCRETE' OR EQUAL ALLOWABLE IN THIS INSTALLATION.)



CITY OF ALBUQUERQUE	
REVISIONS	SEWER SEWER SERVICE REPLACEMENT DETAIL DWG. 2134
	AUG. 1966